

# 2011 Consumer Confidence Report

Water System Name: Sundale Union School System #5400714-001 Report Date: January 5, 2012

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2011.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Ground Water Well: Non Transient Non Community

Name & location of source(s): Well 01 System # 5400714 13990 Ave 240, Tulare, CA 93274

Drinking Water Source Assessment information: \_\_\_\_\_

Time and place of regularly scheduled board meetings for public participation: 2<sup>nd</sup> & 4<sup>th</sup> Tuesdays of each month

For more information, contact: Bob Brooks Phone: (559) 688-7451

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**ppq:** parts per quadrillion or picogram per liter (pg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria Monitored by Tulare Co. EHD	(In a mo.) Not available		More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year) Not available		A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

**TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb) 6/18/09	5	3.4		15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm) 6/18/09	5	0.17		1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

**TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	4/19/04	14.1		none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	4/19/04	97.1		none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring



\*Any violation of an MC or AL is asterisked. Additional information regarding the violation is provided later in this report.

**TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<b>Inorganic Contaminants</b>						
Aluminum (ppm)	12/1/08	0.074		1	0.6	Erosion of natural deposits; residue from some surface water treatment processes
Arsenic (ppb)	12/1/08	4.3		10	0.004	Erosion of natural deposits; runoff from orchards, from glass and electronics production waste
Barium (ppm)	12/1/08	0.026		1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	12/1/08	0.1		2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead (ppb)	12/1/08	51 *		AL=15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Nitrate (as nitrate, NO <sub>3</sub> ) (ppm)	9/14/11	10.2		45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
<b>Radioactive Contaminants</b>						
Gross Alpha Particle Activity (pCi/L)	11/6/07	2.04		15	(0)	Erosion of natural deposits
Uranium (pCi/L)	11/6/07	0.522		20	0.43	Erosion of natural deposits
Total Radium 226 (pCi/L)	11/6/07	0.0198		3	0.05	Erosion of natural deposits
Total Radium 228 (pCi/L)	11/6/07	0.170		2	0.019	Erosion of natural deposits

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Manganese (ppb)	4/19/04	7200		50		Leaching from natural deposits
Total Dissolved Solids (TDS) (ppm)	4/19/04	170		1000		Runoff/leaching from natural deposits
(EC) (umhos/cm) Specific Conductance µS/cm	4/19/04	265		1600		Substances that form ions when in water; seawater influence
Chloride (ppm)	4/19/04	5.3		500		Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	4/19/04	10.2		500		Runoff/leaching from natural deposits; industrial wastes

**TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Turbidity (Units)	4/19/04	0.3		5	none	Soil runoff
Color (Units)	4/19/04	5		15	none	Naturally-occurring organic materials
Odor-Threshold (Units)	4/19/04	1		3	none	Naturally-occurring organic materials

There are no PHGs, MCLGs, or mandatory standard health effects language for these constituents because secondary MCLs are set on the basis of aesthetics.

*\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.*

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead:** Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home’s plumbing. If you are concerned about elevated lead levels in your home’s water, you may wish to have your water tested and/or flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the USEPA Safe Drinking Water Hotline (1-800-426-4791).

**Nitrate:** Nitrate in drinking water at levels above 45 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

### Summary Information for Contaminants Exceeding an MCL, MRDL, or AL or Violation of Any TT or Monitoring and Reporting Requirement

---



---



---



---



---



---



**ATTACHMENT 6**

**Consumer Confidence Report  
Certification Form**

*(to be submitted with a copy of the CCR to the Tulare Co. EHD)*

Water System Name: Sundale Union School

Water System Number: System #5400714-001

The water system named above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified by: Name: Bob Brooks

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Phone Number: (559) 688-7451 Date: \_\_\_\_\_

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: \_\_\_\_\_

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

Posting the CCR on the Internet at www. \_\_\_\_\_

Mailing the CCR to postal patrons within the service area (attach zip codes used)

Advertising the availability of the CCR in news media (attach copy of press release)

Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

Posted the CCR in public places (attach a list of locations)

Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

Delivery to community organizations (attach a list of organizations)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www. \_\_\_\_\_

For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission